


Certificate of Product Approval

Certificate Number: 1262b Issue: 01

QATAR INTERNATIONAL CABLES COMPANY (QICC-NEXANS)

Plot 92320008 Mesaieed Industrial Area P.O. Box 15991 Doha State of Qatar





Cable Types as listed below: ALSECURE PLUS NX400 See Certificate Appendix for details

Standard(s) (see Appendix for details)

BS 7846:2009 Cat F2 IEC 60331-21:1999 EN 50267-2-3:1999

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

burettox.

David Hoare

15 December 2014

15 December 2014

Signed for LPCB

Certification Scheme Manager

Date of Issue

Date of First issue





This certificate and appendix remain the property of BRE Global Ltd and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Garston, Watford, WD25 9XX T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com







Appendix to Certificate No: 1262b Issue: 01 QATAR INTERNATIONAL CABLES COMPANY (QICC-NEXANS)

Product name				LPCB Ref. No.
ALSECURE PLUS NX400				1262b/01
Nominal csa of conductor (mm²)	Core Construction	BS 7846	IEC 60331-21	EN 50267-2-3
16	2, 3 & 4 ⁽¹⁾	F2 ⁽²⁾	Complies ⁽³⁾	Complies
25	2, 3 & 4 ⁽¹⁾	F2 ⁽²⁾	Complies ⁽³⁾	Complies
35	2, 3 & 4 ⁽¹⁾	F2 ⁽²⁾	Complies ⁽³⁾	Complies
50	2, 3 & 4 ⁽¹⁾	F2 ⁽²⁾	Complies ⁽³⁾	Complies
70	2, 3 & 4 ⁽¹⁾	F2 ⁽²⁾	Complies ⁽³⁾	Complies
95	2, 3 & 4 ⁽¹⁾	F2 ⁽²⁾	Complies ⁽³⁾	Complies
120	2, 3 & 4 ⁽¹⁾	F2 ⁽²⁾	Complies ⁽³⁾	Complies
150	2, 3 & 4 ⁽¹⁾	F2 ⁽²⁾	Complies ⁽³⁾	Complies
185	2, 3 & 4 ⁽¹⁾	F2 ⁽²⁾	Complies ⁽³⁾	Complies
240	2, 3 & 4 ⁽¹⁾	F2 ⁽²⁾	Complies ⁽³⁾	Complies
300	2, 3 & 4 ⁽¹⁾	F2 ⁽²⁾	Complies ⁽³⁾	Complies
400	2, 3 & 4 ⁽¹⁾	F2 ⁽²⁾	Complies ⁽³⁾	Complies

Uo/U 600/1000 V

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

burettox.

David Hoare

15 December 2014

15 December 2014

Signed for LPCB

Certification Scheme Manager

Date of Issue

Date of First issue





This certificate and appendix remain the property of BRE Global Ltd and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Garston, Watford, WD25 9XX T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com







Appendix to Certificate No: 1262b QATAR INTERNATIONAL CABLES COMPANY (QICC-NEXANS)

Notes:

- 1. Stranded conductor only.
- 2. In meeting the requirements of BS 7846:2009 Category F2, the ALSECURE PLUS NX400 cables met the requirements for smoke density to EN 61034-2:2005, fire resistance to BS 6387:2013 CWZ and achieved less than 0.5%HCl on the insulation, tapes, filler, bedding and outer covering when tested in accordance with EN 50267-2-1:1999.
- 3. The ALSECURE PLUS NX400 cables met the requirements of IEC 60331-21: 1999 when tested at a temperature of 850°C for a duration of 90mins + 15mins cool down, at a voltage rating of 600V.

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



David Hoare

15 December 2014

15 December 2014

Signed for LPCB

Certification Scheme Manager

Date of Issue

Date of First issue





This certificate and appendix remain the property of BRE Global Ltd and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Garston, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com





Issue: 01